

System Review certificate

NHBC Services Ltd confirms that

System owner: Group Y Limited

System name: Cobalt Balcony System

System manual: Technical Document Rev9 (12/09/2021)

has been reviewed by the NHBC System Review team and as detailed in the System Manual can meet the NHBC Technical Requirements, subject to the exclusions and limitations listed in this certificate.

This certificate is valid until such time as it is no longer published or authorised by NHBC. Readers are advised to check the validity and latest issue number of this certificate by either referring to our website at nhbc.co.uk/systemreview or contacting NHBC directly.

NHBC Services Ltd has undertaken a technical review of the System manual as set out in line with the NHBC System Review Technical Document for Innovative systems. The NHBC System Review Service is intended solely to provide confidence that the Innovative system meets NHBC Standards and is not intended as evidence of performance for any other purpose. Appraisal of the Innovative system against building regulations is not carried out as part of this Service.

NHBC reference: 3697

First issued: 06/12/2021

Version number: 04.1

Revised on: 26/01/2026

NHBC System Review is not an independent accreditation scheme or any form of performance guarantee, and third parties should engage with the relevant manufacturer on performance of their product. No documentation, information and advice relating to NHBC System Review may be adapted, disclosed, or distributed to any third party. NHBC Services Ltd accepts no duty of care and assumes no responsibility to any third party. Any third party who chooses to rely upon an NHBC System Review certificate (or any documentation, information and advice relating to the NHBC System Review service) shall do so entirely at their own risk and NHBC Services Ltd accepts no duty of care or liability for any damage or loss, however caused, in connection with the use of or reliance on any documentation, information and advice relating to NHBC System Review.



NHBC reference: 3697.04.1

System description

The Cobalt System is a prefabricated mild steel and aluminium balcony for attachment to low-and high-rise residential buildings, including buildings over 18m. It is designed for single family dwelling units, limited use communal areas within blocks of flats, in accordance with Category A5 (Domestic and residential activities; communal areas within flats of limited use) of BS EN 1991-1-1 (UK Annex). Flats of limited use are defined as flats not more than three storeys in height and with no more than four self-contained dwelling units per floor accessible from one staircase.

The balcony chassis is the primary structural element common to all Cobalt variations, formed from galvanised mild steel components and aluminium extrusions. Standard configurations use galvanised mild steel "arms" perpendicular from the building façade, while the Cobalt Free Standing variant incorporates a full width steel "back beam". The System connects to the building via proprietary cast-in or bolt-on building connector stubs assessed on a project-specific basis. An aluminium drainage tray and interlocking aluminium soffit panels are fixed to the chassis, which supports either powder-coated aluminium decking or stone tiles, together with a range of prefabricated balustrade options.

Exclusions and limitations

Additional requirements must be met in order for a new home to qualify for Buildmark cover. Buildmark cover for new homes will only be issued to Builders or Developers in accordance with the latest version of the NHBC Rules (a copy of which can be found at [nhbc.co.uk](https://www.nhbc.co.uk)).

- The overall design and structural limitations must be assessed on a project-by-project basis by a suitably qualified Structural Engineer.
- For buildings over 50m, or with unconventional (e.g., non-rectangular) layouts, or near other tall buildings, net wind pressures on guarding must be determined through detailed scale-model wind tunnel tests following BS EN 1991-1-4, (with UK National Annex), and PD 6688-1-4.
- The system has been designed to a minimum vertical frequency of 5Hz (tested to 8.2Hz) in accordance with BS 8679:2020.
- Deflection has been restricted to a maximum of 5mm under static 2kN concentrated load in accordance with BS 8679:2020.
- The specification and design of proprietary cast in or bolt-on balcony connector stubs including the cantilever arms, fire stopping, and cavity barriers are outside the scope of this certificate.

National House-Building Council (NHBC) is authorised by the Prudential Regulation Authority and regulated by the Financial Conduct Authority and the Prudential Regulation Authority in respect of carrying on its insurance business and its insurance distribution activities. NHBC is registered in England and Wales under company number 00320784. NHBC's registered address is NHBC House, Davy Avenue, Knowlhill, Milton Keynes, Bucks, MK5 8FP.

Note that only certain parts of NHBC's products and services are within the scope of UK financial services regulation. For more information on our products and services, please see our website [nhbc.co.uk](https://www.nhbc.co.uk) or your NHBC product documentation.